



Tom Barrett
Mayor

Bevan K. Baker, FACHE
Commissioner of Health

Joe'Mar Hooper, MPA
Health Operations Administrator

www.milwaukee.gov/health

Frank P. Zeidler Municipal Building, 841 North Broadway, 3rd Floor, Milwaukee, WI 53202-3653 phone (414) 286-3521 fax (414) 286-5990

Routine Food

HUBBARD & ASSOCIATES NA, INC.

5/20/2014

MJ Cafe
6901 W Brown Deer Rd
Milwaukee, WI

The following list of violations of the Wisconsin Administrative Code as adopted by reference in the Milwaukee Code of Ordinances Chapter 68, and/or other City ordinance(s) must be corrected as soon as possible but not later than the date specified. A re-inspection fee may be assessed if the violation is not corrected by that date. An inspection fee may be charged for any repeat violations.

CDC Risk Code Factor Violation(s)

Code Number	Description of Violation	Correct By
Cross Contamination		
3-304.11	1. Greasy tongs were hanging on the oven handle bars. Kitchen not in use at time of inspection. Wash equipment every day. 2. Cutting board at the prep sink was heavily grooved and stained. Clean, replace or resurface. Food equipment must be clean and sanitized before used with food.	6/3/2014
Improper Hold		
3-501.17	Undated feta cheese in the prep cooler and gyro meat in the upright cooler. Ready-to-eat potentially hazardous food held for more than 24 hours must clearly marked to indicate the day by which the food is to be consumed on the premise, sold, or discarded.	6/3/2014
CDC Risk Violation(s):	2	

Good Retail Practice Violations(s)

Code Number	Description of Violation	Correct By
4-301.14	Inspector could not get the hood ventilation to come on. Repair to code. Provide an approved ventilaton hood for all required cooking equipment.	6/3/2014
5-103.11	Inspector was unable to get hot water in both bathrooms. Ran water for at least a minute without success. You may have to install mini hot water on demand units under the sinks if water does not get hot. Provide an adequate water supply.	6/3/2014



Tom Barrett
Mayor

Bevan K. Baker, FACHE
Commissioner of Health

Joe'Mar Hooper, MPA
Health Operations Administrator

www.milwaukee.gov/health

Frank P. Zeidler Municipal Building, 841 North Broadway, 3rd Floor, Milwaukee, WI 53202-3653 phone (414) 286-3521 fax (414) 286-5990

5-202.11

Install a vacuum breaker onto the mop sink faucet. Properly repair plumbing.

6/3/2014

Good Practice Violation(s): 3

Total Violations: 5

Notes:

Operator was not present at time of inspection. Caterer renting kitchen signed report and report emailed to Karen Hubbard by inspector. klg

On 5/20/2014, I served these orders upon HUBBARD & ASSOCIATES NA, INC. by leaving this report with

Inspector Signature (Inspector ID:84)

Operator Signature